



NOTE:
INSTALLATION OF THE METER
BOX IN DRIVEWAY IS PROHIBITED
WITHOUT PRIOR APPROVAL
FROM CITY ENGINEER.



Dr.	JP	No.	Date	Revision	Appr.	Approved By:
Ch.	LC					<i>Charles Swinley</i> 2/24/14 Date
Date	1/27/14					Charlie Swinley City Engineer / Deputy Public Works Director RCE No. 52842



CITY OF LODI

PUBLIC WORKS DEPARTMENT

DUAL WATER SERVICE (DUPLEX)

MATERIAL LIST

FITTING	SIZE	BASIC FEATURE	INLET CONNECTION	OUTLET CONNECTION	MANUFACTURER'S NOTE
1 METER COUPLING	1"	BRASS W/ NL LISTED	1" MNPT	3/4" MALE METER THREAD	McDONALD 74619 (3/4"x1"x2.18")
2 U-BRANCHES	1"	STANDARD U-BRANCH	1" MNPT	3/4" MNPT	McDONALD 709UFCW (1" x 3/4" x 6.5")
3 METER VALVE	1"	BALL VALVE WITH LOCKWING	1" PE CTS COMPRESSION	1" STRAIGHT THREAD SWIVEL NUT	McDONALD 76101MW (1" x 3/4" x 3/4")
4 METER SPOOL	1"x9"		1"	1"	1" SCH 80 PVC
5 CUSTOMER VALVE ANGLE STOP	1"	FULL PORT ANGLE BALL VALVE	METER SWIVEL NUT	1" FIPT	McDONALD 74604B WITH HANDLE #6120B
6 SERVICE BOX		LID TO READ WATER	N/A	N/A	CHRISTY B36 BOX W/ FL36D FIBRELYTE LID

2 of 2

Dr. JP	No.	Date	Revision	Appr.	Approved By:	STD PLAN
Ch. LC					<i>Charles Swinley</i>	418
Date 1/23/14					2/24/14 Date	
					Charlie Swinley City Engineer / Deputy Public Works Director RCE No. 52842	