CITY OF LODI

PUBLIC WORKS DEPARTMENT

2" WATER SERVICE FOR 1-1/2" OR 2" METER MATERIAL LIST

FITTING (A)	SIZE	BASIC FEATURE	INLET CONNECTION	OUTLET CONNECTION	MANUFACTURER'S NOS.
SADDLES 1	2"	FOR C1-AC & DUCTILE IRON PIPE DUCTILE IRON DOUBLE STRAP SADDLE NO SINGLE STRAP SADDLES		IPT	ROCKWELL 313 APAC 102 OTHER MANUFACTURERS WITH SIMILAR DESIGNS O.K.
SADDLES	2"	FOR C900 PIPE		IPT	ROMAC 101S MUELLER H1349 WITH 1P THREAD
CORP. STOP 2	2"	BALL VALVE	2" IPT	2" CTS COMP	A.Y. MCDONALD 4704B-22 OR APPROVED EQUAL
CORP. STOP	2"	BALL VALVE	2" IPT	2" IPT	A.Y. MCDONALD 3122B OR APPROVED EQUAL

Dr.	No.	Date	Revision	Appr.
	1	9/03	ADDED END CAP	
Ch. WS	2	2/04	REVISED PAGE 4	
	3	2/05	REVISED PAGE 1	
Date	4	6/10	REVISED PER AB 1953 REQ'S.	

Approved By:

Charlie Swimley — Date
City Engineer / Deputy Public Works Director
RCE No. 52842

STD PLAN

412